

FIRE SAFETY CERTIFICATE

File No :10104/04

Dated: 11 Mar 2024

It is certified that Nos **P-3, P-04A, P-04B, P-05, P-06, P-07, P-19, 33, P-37, P-N/01, P-N/02** (Name of the building premises) at **Charaibahi Military Station, PO- Charaibahi, Distt : Jorhat (Assam)** (address) Comprised of - Basement(s) and -- (upper floors) owned/occupied by **Army Public School Jorhat** have complied with the Fire prevention and fire safety requirements in accordance with rules of State/UT Fire Service Rules, and verified by the officers concerned of Fire Service on 24 Mar 2023 (date of inspection) in the presence of **Staff Officer (Education), HQ 41 Sub Area, C/o 99 APO** (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto Classes **I-XII (X/XII)** with effect from **11 Mar 2024** for a period of 05 years in accordance with rule and subject to compliance of the specific conditions as appended :-

- (a) Refilling of Fire Extinguishers on due date.
 (b) I
 (c) I

Issued on 12 Mar 2024 at 12:00h by

*Strike out whichever is not applicable



Signature: [Signature]
 Name: **S/O CHAIRMAN / एन.ओ. टू चेयरमैन**
 Designation: **ARMY PUBLIC SCHOOL**
आर्मी पब्लिक स्कूल
JORHAT/ जोरहाट
 Name & Address of Department/Office

To

Army Public school, Jorhat
Charaibahi Military Station
Jorhat - 785006
 (Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled due to
 (Reasons to be recorded)

(Name and designation of the authorised signatory)

NA

*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Safety Point

Licence No. - 4194

A House of everything in FIRE FIGHTING & INDUSTRIAL SAFETY EQUIPMENT

A. T. Road, Kenduguri, Near Petrol Pump, Jorhat - 785 010

☎ 94350 91609 (M) / 97067-09707 (M)

Reg. S. S. I. Unit Govt. of Assam

FIRE PROTECTION & SAFETY ENGINEERS

No. 41

Date : 24/5/2023



Certified that following Fire Extinguishers were Tested & or Refilled and Hydro Test Serviced by us at
To, Army public School
Jorhat

Sl. No.	Type of Fire Extinguisher	Qty. Refilled	Qty. Rejected
1.	Dry Chemical Powder Type Capacity Fire Extinguisher		
2.	Dry Chemical Powder Type Capacity Fire Extinguisher		
3.	ABC Stored Pressure Type <u>9kg</u> Capacity Fire Extinguisher	<u>9 Nos</u>	<u>Nil</u>
4.	ABC Stored Pressure Type Capacity Fire Extinguisher		
5.	ABC Stored Pressure Type <u>2kg</u> Capacity Fire Extinguisher	<u>12 Nos</u>	<u>Nil</u>
6.	Co ₂ Type <u>4.5kg</u> Capacity Fire Extinguisher	<u>2 Nos</u>	<u>Nil</u>
7.	M/ Foam Type <u>9lt</u> Capacity Fire Extinguisher	<u>9 Nos</u>	<u>Nil</u>
TOTAL		<u>32 Nos</u>	

Last Tasting / Demonstration Program

DCP. - Type	1. Co2 Cartridge	ABC Type	✓5. ABC Powder	CHECKING THREE MONTHS <i>Antika</i> 9435091609
	2. DPC Powder		✓6. Pressure -	
	3. DCP Hose		✓7. Hope Pipe	
	4. Paint		Mfd. Date.	

ABC & DCP-9KG/10KG SHOULD NOT BE OLDER THAN 10 YEARS

Hydrotest of 30kg / um² of 2.5 mins of Ultrasonic thickness testing for DCP -9kg / 10kg 1kg/2kg CHECKING FIVE YEARS Checking Date

Co² 2kg / 1kg Hydrotest CHECKING THREE MONGHTS Checking Date
Refilling Co² Hose Pipe Paint. Co² 2kg/1kg. Mfd. Date

CO2 2KG / 1KG SHOULD NOT BE OLDER THAN 15 YEARS

Hydrotest of 30 kg/um² of 2.5 mins of Ultrasonic thickness testing for Co²-2kg/1kg. CHECKING FIVE YEARS Checking Date

Reason of Rejection :

FIRE CAN START ANY TIME

Date of Refilling

24/5/2023

Next Due Date

23/5/2024

